

Certificate of Compliance

Certificate Number(s):

UL-US-2319226-3

Report Reference:

E534647-20230505

Issue Date:

2026-06-25

Issued to:

HANGZHOU ZION COMMUNICATION CO.,LTD

No. 68 Huaqiao Road, Xinxiqiao Village, Jincheng Street, Lin' an District, Hangzhou City, Zhejiang, 311300, CN

This certificate confirms that representative samples of:

ZOYR - Reaction to Fire and Fire Resistance of Cables Evaluated in accordance with International Standards

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

EN 50200:2015

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch

UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2319226-3
Report reference: E534647-20230505
Issue Date: 2026-06-25

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Cables Evaluated International Standards

Model(s): 300/500 V fire resistant screened cables, 2 Core Cu/Silicone/ Fiber glass tape/TC Drain wire/Al Foil Screened/(LTS1/LTS3) sheathed, Class 1 Conductor,
3 & 4 Cores Cu/Silicone/ Fiber glass tape/TC Drain wire/Al Foil Screened/(LTS1/LTS3) sheathed, Class 1 Conductor,
3Core - Cu/Silicone/ Fiber glass tape/TC Drain wire/Al Foil Screened/(LTS1/LTS3) sheathed, Class 5 Conductor,
4Core - Cu/Silicone/ Fiber glass tape/TC Drain wire/Al Foil Screened/(LTS1/LTS3) sheathed, Class 5 Conductor
Model(s): 300/500 V fire resistant screened cables, 2 Core Cu/Silicone/ Fiber glass tape/TC Drain wire/Al Foil Screened/(LTS1/LTS3) sheathed, Class 5 Conductor *Fire alarm Cables 2 Core*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

